

December 19, 2014

Tridel Corp.
4800 Dufferin Street
Toronto, Ontario
M3H 5S9

5 CAMDEN STREET, TORONTO, CANADA M5V 1V2

T. 416.598.0554

F. 416.598.1705

E. info@teepiearch.com

W. teepiearch.com

Attention: Mr. Steve Daniels, Development Manager

Dear Mr. Daniels:

Re: Site Plan Application No 13:144963 STE 20SA
571 Dundas West

Please find enclosed our resubmitted documents in response to the memorandum regarding the above noted file from Nhat Anh-Nguyen, dated December 9, 2014.

1.1 Fire Services

1.2.1 Block 11

- a) Refer to drawing A 102 Site Plan Block 11, Reissued for Site Plan Approval, dated 2014/12/22 enclosed with revisions clouded. Two additional remote siamese connections have been added at the southeast corner of the site. The fire department connections are within 45 meters of the existing fire hydrant, as dimensioned and noted.


1.3 Solid Waste Services

1.3.1 Residential Component - Block 11

- a) Refer to section 1 / A 404 enclosed with revisions clouded The Type G loading space has a maximum slope of 2%.

Please contact me if you require any further information.

Yours very truly,
Teepie Architects^{INC.}



Jeffery Hanning
B.E.S., B. Arch., LEED AP, OAA
Senior Architect