

S.I. #E-1
ELECTRICAL WORK
FOR
ALEXANDRA PARK

DELTERA

NOVATREND ENGINEERING GROUP LTD.

Date: January 28, 2015

This Site Instruction is issued to incorporate the security changes, Elevator Shop Drawing and Suite Lighting Changes

1. Reference drawing E-1 Layout (Issued)
 - a. Revised drawing list.
2. Reference drawing E-3 Layout (Issued)
 - a. Relocated a CR in Vestibule P110 as shown.
 - b. Deleted two DO, one DC, ES and two Push Button in Vestibule # P101 as shown.
3. Reference drawing E-4 Layout (Issued)
 - a. Changed a ML to ES, and deleted a pull station, DC and ES in Vestibule # 142 as shown.
 - b. Changed a ML to ES, and Deleted a MD in Vestibule # 141 as shown.
 - c. Deleted a DO at Door near Corridor # 154 as shown.
 - d. Added a CR, DC and ES at door near Corridor # 160 as shown.
4. Reference drawing E-5 Layout (Issued)
 - a. Added a CR, DC and ES at door near Corridor # 113 as shown.
5. Reference drawings E-4, E-5, E-8, E-9, E-10, E-11, E-14, E-16, E-17, E-19, and E-22 to E-28 Layout (Issued)
 - a. Removed all shower pot lights that are over any bath tubs.
 - b. Added shower pot lights over all shower stalls.
6. Reference drawing E-29 Layout (Issued)
 - a. Revised Elevator Machine Room Layout as per Elevator Shop Drawing.
7. Reference drawing E-30 Layout (Issued)
 - a. Revised Elevator motor to 25HP, and revised fuse size accordingly as per Elevator Shop Drawing as shown.