

SITE INSTRUCTION NO. M-9  
MECHANICAL WORK  
FOR  
ALEXANDRA PARK

DELTERA

NOVATREND ENGINEERING GROUP LTD.

---

Date: October 8, 2015

Changes in this notice are being issued to address acoustic engineer's comments and generator catalytic converter.

1. Reference drawing M-3 (Issued)
  - a. **Revision:** Silencer added for EF-17
2. Reference drawing M-4 (Issued)
  - a. **Revision:** Silencer added for EF-18
3. Reference drawing M-5 (Issued)
  - a. **Revision:** Revised as per additional Steam room and change in layout.
4. Reference drawing M-6 (Issued)
  - a. **Revision:** Revised as per additional Steam room and change in layout.
  - b. **Revision:** 2x Dectron dehumidification DH-B added for Steam room.
5. Reference drawing M-8, 9, 12, 13, 18, 20, 21, 23, 26, 28, 29, 31 (Issued)
  - a. **Revision:** Added Gas Lockable Shut-off valve. Valves to be labeled with suite # for the suite it serves.
6. Reference drawing M-10 (Issued)
  - a. **Revision:** Revised as per additional Steam room.
  - b. **Revision:** 2x Dectron dehumidification DH-B added for Steam room.
7. Reference drawing M-15 (Issued)
  - a. **Clarification:** Revised FCU orientation that was shown incorrectly.
8. Reference drawing M-17 (Issued)
  - a. **Clarification:** Revised FCU orientation that was shown incorrectly.
9. Reference drawing M-19 (Issued)
  - a. **Clarification:** Revised FCU orientation that was shown incorrectly

10. Reference drawing M-30 (Issued)

- a. **Revision:** Added Gas Lockable Shut-off valve. Valves to be labeled with suite # for the suite it serves.
- b. **Revision:** Revised suite layout 1208 as per Arch. Changes.