

| TO | FROM |
|--------------------------------|--|
| TRIDEL | MEHARI MANNA SEARE |
| ATTN DAVID ZEEGEN | PROJECT NAME ARISTO AT AVONSHIRE |
| | PROJECT No. 10126 |
| PHONE (416) 736-2536 | DATE 2013-07-26 |
| CC | RE: SEE BELOW |

DETAILS

Please note that this site instruction becomes part of the drawing package, issued for tender, January 17, 2012.

| ITEM | DESCRIPTION | DRAWING REFERENCE |
|------|---|-------------------|
| 1. | PARKING LEVEL RCP | Reference |
| | 1.01. Details 1, 3 and 5: Revised lighting layout and spacing as shown. Dimensions added. Details 2, 4 and 6: Dimensions added. | ID0.2 |
| 2. | GROUND & SECOND FLOOR AMENITIES RCP | Reference |
| | 2.01. Dimensions added through out to clarify placement of light fixtures. Light fixture type in Property Management Kitchen changed from LT10 to LT1. Light fixture type at end corridor near Mail Room changed from LT1 to LT2. Added one light fixture at BOH Storage behind Concierge Desk | ID1.2 |
| | 2.02. Dimensions added through out to clarify placement of light fixtures. Revised Elevator Lobby lighting layout to coordinate with Electrical Dwgs. New detail (3/ID2.1) added to clarify placement of lights in and around Steam Room. | ID2.2 |
| 3. | CORRIDOR RCP | Reference |
| | 3.01. Dimensions added through out to clarify placement of light fixtures. | ID3.1.2 |
| | 3.02. Dimensions added through out to clarify placement of light fixtures. | ID3.2.2 |

END OF SI-ID09