

TO	FROM
TRIDEL	MEHARI MANNA SEARE
ATTN DAVID ZEEGEN	PROJECT NAME ARISTO AT AVONSHIRE
	PROJECT No. 10126
PHONE (416) 736-2536	DATE 2013-08-02
CC	RE: SEE BELOW

DETAILS

Please note that this site instruction becomes part of the drawing package, issued for tender, January 17, 2012.

ITEM	DESCRIPTION	DRAWING REFERENCE
1.	ELEVATOR LOBBY AND CORIDOR RCP	Reference
1.01.	Details 2 & 4: Dimensions added to clarify placement of light fixtures. Light fixture quantity at Residential Corridors increased by five to match Electrical Drawings. Light fixture layout at Elevator Lobbies revised as shown, quantity decreased by one, compared to Electrical Dwgs,	ID3.3
1.02.	Details 2 & 4: Dimensions added to clarify placement of light fixtures. Light fixture quantity at Residential Corridors increased by five to match Electrical Drawings. Light fixture layout at Elevator Lobbies revised as shown, quantity decreased by one, compared to Electrical Dwgs	ID3.4
1.03.	Details 2 & 4: Dimensions added to clarify placement of light fixtures. Light fixture quantity at Residential Corridors increased by six at Building C (detail 2), and by five at Building D (detail 4) to match Electrical Drawings. LT11 light fixtures at transfer floors re-named LT11A (spec still matches approved shop dwgs). Light fixture layout at Elevator Lobbies revised as shown, quantity decreased by one, compared to Electrical Dwgs,	ID3.5
1.04.	Detail 2: Dimensions added to clarify placement of light fixtures. Light fixture quantity at Residential Corridors increased by four to match Electrical Drawings. Details 4 & 6: Dimensions added to clarify placement of light fixtures. Light fixture quantity at Residential Corridors increased by four to match Electrical Drawings. LT11 light fixtures at transfer floors re-named	ID3.6

ITEM	DESCRIPTION	DRAWING REFERENCE
	<p>LT11A (spec still matches approved shop dwgs). Details 2, 4 and 6: Light fixture layout at Elevator Lobbies revised as shown, quantity decreased by one, compared to Electrical Dwgs,</p>	
1.05.	<p>Detail 2: Dimensions added to clarify placement of light fixtures. Light fixture quantity at Residential Corridors increased by four to match Electrical Drawings. Details 4 & 6: Dimensions added to clarify placement of light fixtures. Light fixture quantity at Residential Corridors increased by four (detail 4), and by three (detail 6) to match Electrical Drawings. LT11 light fixtures at transfer floors re-named LT11A (spec still matches approved shop dwgs). Details 2, 4 and 6: Light fixture layout at Elevator Lobbies revised as shown, quantity decreased by one, compared to Electrical Dwgs,</p>	ID3.7

END OF SI-ID10
