

TORONTO GREEN STANDARD VERSION 2.0 – CHECKLIST

For New Mid to High Rise Residential and all New Non-Residential Development
Complete in conjunction with the full Toronto Green Standard and Specifications.

The Toronto Green Standard (TGS) is a new set of performance measures, with supporting guidelines for new development, to pursue its to promote sustainable site and building designs that address Toronto urban environmental pressures, its quality, climate change and energy efficiency, and the quality of life of its residents. The checklist is a tool to help developers understand the requirements of the TGS and to ensure that the project meets the requirements of the TGS. The checklist is a tool to help developers understand the requirements of the TGS and to ensure that the project meets the requirements of the TGS. The checklist is a tool to help developers understand the requirements of the TGS and to ensure that the project meets the requirements of the TGS.

Application Submitted

☒ Site Plan Control ☐ Zoning Bylaw Amendment ☐ Draft Plan of Subdivision

Office Use Only

District Office: ☐ North York District ☐ Toronto East York District ☐ Scarborough District

Date Received: _____

Is this checklist received from an earlier submission? ☐ Yes ☐ No

Property and Applicant

Address of Subject Land (Street Number/Name): Merchants Wharf and Bloor-Yonge Street

Applicant Name: _____

Telephone: _____

E-mail: _____

Registered Owner: _____

Gross Floor Area: _____

Number of Storeys: _____

Project Information includes a narrative of your project highlighting green features or performance measures. The building includes 227 mixed-use units and 30 affordable housing units. This checklist is for the portion of the building, which is pursuing TGS Tier 2 and LEED Platinum certification. Energy efficiency measures include high performance envelope, in-situ ventilation heat recovery, efficient heating and cooling equipment, efficient light fixtures coupled with occupancy sensors, responsive elevators, and other strategies to ensure that it performs at least 20% more efficiently than SB-10 requirements. Low flow plumbing fixtures are selected for optimal water efficiency. Material selection favours recycled, regional, and low toxicity products.

* Tier 1 performance measures are required by the City and must be addressed as part of your proposed development application. Tier 2 performance measures are optional and may be addressed as part of your proposed development application. Tier 3 performance measures are optional and may be addressed as part of your proposed development application. Check here if you intend to achieve Tier 2 of the Toronto Green Standard (complete pages 9-12).



TORONTO GREEN STANDARD VERSION 2.0 – CHECKLIST

For New Mid to High Rise Residential and all New Non-Residential Development
Complete in conjunction with the full Toronto Green Standard and Specifications.

TIER 1: AIR QUALITY

Section	Development Feature	Tier 1 Required Performance Measure Summary	Description (How is this performance measure being met?)	Reference to Plans, Drawings or Reports
AQ.1.1	Low-Emitting Vehicle Spaces	Physical spaces for future electric vehicle charging installed at dedicated parking above ground level.	A minimum of 100 automobile parking spaces are required under the City of Toronto. The City of Toronto is required to provide dedicated parking spaces for electric vehicles. The City of Toronto is required to provide dedicated parking spaces for electric vehicles. The City of Toronto is required to provide dedicated parking spaces for electric vehicles.	Site Plan # A1-1 Underground Garage Plan # Other #
AQ.1.1	Low-Emitting Vehicle Spaces	Physical spaces for future electric vehicle charging installed at dedicated parking above ground level.	A minimum of 100 automobile parking spaces are provided for this development. Dedicated carpool parking is provided for 16 spaces.	Site Plan # A1-1 Underground Garage Plan # A2.1-A2.3 Other #
AQ.2.1	Recycling Parking Rates	Minimum bicycle parking rates	Zoning Bylaw requires 100 residential parking spaces. There is no commercial parking requirement. Provided: 207 residential and 10 commercial spaces. 12 car charging stations will be provided, along with provisions for future EV charging at 57 spaces.	Site Plan # A1-1 Underground Garage Plan # A2.1-A2.4 Other #
AQ.2.2	Long-term bicycle parking location	Long-term parking in secure bicycle parking facility or purpose-built bicycle facility	Long-term parking is distributed throughout P1 thru P4, P1, P4 Condo and 10 Retail (P2, P3, P4, P4 Condo).	Site Plan # A1-1 Underground Garage Plan # A2.1-A2.3 Other #
AQ.2.3	Short-term bicycle parking location	Short-term bicycle parking in a highly visible and publicly accessible location	Short-term parking is located on P1, P3, P4 Condo and 6 Retail. Additional bike racks are located at grade along Merchants Wharf, just outside the project boundary.	Site Plan # A1-1 Underground Garage Plan # A2.1-A2.3 Other #
AQ.2.4	Shower & change facilities	Shower and change facilities (non-residential only)	2 showers with change rooms will be provided for use by commercial tenants. An additional shower will be provided for residential property management and security staff located on L1 mezz.	Site Plan # A1-1 Other # A2.4

TORONTO GREEN STANDARD VERSION 2.0 – CHECKLIST

For New Mid to High Rise Residential and all New Non-Residential Development
Complete in conjunction with the full Toronto Green Standard and Specifications.

Section	Development Feature	Tier 1 Required Performance Measure Summary	Description (How is this performance measure being met?)	Reference to Plans, Drawings or Reports
AQ.3.1	Connectivity	Safe, accessible pedestrian routes that connect with off-site pedestrian networks and priority destinations	Building is connected to waterfront promenade, and pedestrian paths leading to off-site pedestrian networks, transit stops, Queen's Quay, and parks. Shown on Masterplan drawing.	Floor Plan # A1-1 Other # A1.3
AQ.3.2	Sidewalk space	Protected sidewalk of at least 2.1 m wide to accommodate pedestrian flow	Footcandle walkways are 2.4 m wide. Shown on Masterplan drawing.	Site Plan # A1-1 Landscape Plan # Other # A1.3
AQ.3.3	Weather protection	Covered outdoor seating areas	All entrances to lobbies have covered areas where residents may wait while being protected from environmental factors.	Site Plan # A1-1 Other # A2.3
AQ.3.4	Pedestrian specific lighting	Pedestrian scale lighting	All lighting for the pedestrian realm will be a combination of building-mounted wall sconces and street lights. All lighting fixtures will be cut-off, directed downwards to minimize light pollution.	Site Plan # A1-1 Building Cross Section # Other #
AQ.4.1	Urban Heat Island Reduction (At Grade)	One of the following is provided: a) High-albedo surface materials OR b) Green roof or low-impact green roof OR c) Shade from structures covered by solar panels OR d) Combination of above options	100% of parking will be in underground parking garage. The specified green roof is an SB-10 (2.4 m) Plan to the north of the project. It was approved for the entire development to provide a consistent appearance throughout, and has already been installed along Merchants Wharf. Product selection is outside the scope of this design team.	Landscape Plan # A1-1 Other # A2.1 - A2.2

TORONTO GREEN STANDARD VERSION 2.0 – CHECKLIST

For New Mid to High Rise Residential and all New Non-Residential Development
Complete in conjunction with the full Toronto Green Standard and Specifications.

Section	Development Feature	Tier 1 Required Performance Measure Summary	Description (How is this performance measure being met?)	Reference to Plans, Drawings or Reports
EHG.1.1	Green or cool roof	Choose the applicable category: a) Green roof by Vegetation OR b) Green roof by low-impact green roof OR c) Green roof by low-impact green roof OR d) Green roof by low-impact green roof OR	>100,000 m² GFA, therefore 60% green roof coverage required. The green roof is a low-impact green roof. Total available roof area is approximately 1,700 m². Green roof required: 1,020 m². Green roof provided: 1,100 m².	Site Plan # A1-1 Roof Plan # A2.4, 2.9

TIER 1: GREENHOUSE GAS EMISSIONS/ENERGY EFFICIENCY

Section	Development Feature	Tier 1 Required Performance Measure Summary	Description (How is this performance measure being met?)	Reference to Plans, Drawings or Reports
EHG.1.1	Energy efficiency	Design building to achieve at least 10% energy efficiency improvement over the current Ontario Building Code	Building is designed to exceed 20% energy efficiency improvement over SB-10.	Energy Efficiency Report # Other # A2.1 a) Small Buildings Checklist
EHG.1.2	On-site renewable energy	City-owned buildings and at ABCs: total renewable energy devices	N/A	Feasibility study

TORONTO GREEN STANDARD VERSION 2.0 – CHECKLIST

For New Mid to High Rise Residential and all New Non-Residential Development
Complete in conjunction with the full Toronto Green Standard and Specifications.

TIER 1: WATER QUALITY, QUANTITY AND EFFICIENCY

Section	Development Feature	Tier 1 Required Performance Measure Summary	Description (How is this performance measure being met?)	Reference to Plans, Drawings or Reports
WQ.1.1	Stormwater management	Adherence to Toronto and Southwest Control Guidelines for Urban Construction	ESCC plan includes stormwater control measures, catch basins, sedimentation tanks, the construction vehicle wash mat, and any internal drainage system required to store drainage to control points.	Site Plan # A1-1 Other #
WQ.2.1	Stormwater balance	Stormwater retained on-site to the same level of annual volume as the pre-development conditions	Quantity of stormwater runoff will not exceed pre-development conditions. Retention of stormwater will be provided through underground storage tanks, and retention of stormwater will be provided through underground storage tanks.	Site Plan # A1-1 Underground Garage Plan # Other #
WQ.2.2	Stormwater retention & reuse	One of the following is provided: a) The first 10 mm of rainfall is retained on-site OR b) Maximum allowable annual runoff volume is no more than 50% of the total average annual rainfall depth	Runoff from a 15mm storm event will be captured from the elevated impervious areas, and retained on-site through underground storage tanks, and retention of stormwater will be provided through underground storage tanks.	Site Plan # A1-1 Underground Garage Plan # Other #
WQ.3.1	Total suspended solids (TSS)	Remove 90% of total suspended solids based on the pre-development level of maintenance	All runoff from site will be non-erosive, non-toxic and non-hazardous, and can be considered clean for quality purposes. Capture of and 10 mm of rainfall will provide water quality improvements (as per first flush theory). Bayview OGS and future BVGP extension will provide additional off-site treatment.	Site Plan # A1-1 Underground Garage Plan # Other #
WQ.3.2	E coli reduction	Control the amount of E. coli directly entering Lake Ontario and surrounding areas	This requirement is satisfied by the existing UV treatment facility plant already installed in Stormwater Control, and the existing UV treatment facility plant already installed in Stormwater Control, and the existing UV treatment facility plant already installed in Stormwater Control.	Site Plan # A1-1 Underground Garage Plan # Other #
WQ.4.1	Drought tolerant landscaping	Water efficient plant material provided at least 50% of landscaped site area	Selected green roof (or equivalent), planted with a variety of plants, will be used to the majority of the green roof area. Most of the remaining landscape will use native and adaptive species.	Landscape Plan # A1.1 Other #

TORONTO GREEN STANDARD VERSION 2.0 – CHECKLIST

For New Mid to High Rise Residential and all New Non-Residential Development
Complete in conjunction with the full Toronto Green Standard and Specifications.

TIER 1: ECOLOGY

Section	Development Feature	Tier 1 Required Performance Measure Summary	Description (How is this performance measure being met?)	Reference to Plans, Drawings or Reports
EC.1.1	Tree protection	Adherence to the Tree Protection Policy and Specifications for Construction Sites	No trees are large enough to be considered protected.	Arborist Report # A1-1 Site Plan # A1-1 Tree Preservation Plan # Other #
EC.1.2	Preservation of mature trees	Protect and retain all trees that are 50 cm or more DBH from injury or removal	There are no trees over 30cm in diameter onsite.	Arborist Report # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
EC.1.3	Re-tree protection	Within the Re-tree Protected Area, protect and retain trees of all diameters	Not applicable to site.	Arborist Report # A1-1 Site Plan # A1-1 Tree Preservation Plan # Other #
EC.1.4	Street tree retention	Protect and retain all trees adjacent to City of Toronto streets and railways and City-owned Parkland	The construction team will take every precaution to prevent damage to existing trees. If damage occurs, they will be replaced at the end of construction.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
EC.2.1	Tree planting	Tree canopy cover distributed across site area and public boulevard	Edge/water streetscape design is not yet finalized and is being done by a different design team. Trees will be included in the design, if feasible.	Landscape Plan # A1-1 Other #
EC.2.2	Soil volumes	Provide all trees planted with a minimum volume of 30 m³ of high quality soil per tree	Required soil volumes will be provided for street trees adjacent to site.	Landscape Plan # A1.1, A2.1, A2.2 Other #

TORONTO GREEN STANDARD VERSION 2.0 – CHECKLIST

For New Mid to High Rise Residential and all New Non-Residential Development
Complete in conjunction with the full Toronto Green Standard and Specifications.

Section	Development Feature	Tier 1 Required Performance Measure Summary	Description (How is this performance measure being met?)	Reference to Plans, Drawings or Reports
EC.2.3	Tree along street frontages	Plant large shade trees along all street frontages	Edge/water streetscape design is not yet finalized. Final design plan will be included in the design, if feasible.	Landscape Plan # A1-1 Other #
EC.2.4	Trees in parking lots	Plant shade trees throughout the parking lot interior	N/A. There is no surface parking.	Arborist Report # A1-1 Landscape Plan # Other #
EC.2.5	Watering program	Provide a watering program for trees for at least the first 2 years after planting	Irrigation program will be in place for the first two years after planting. Trees will be irrigated with hand-watered irrigation or permanent irrigation system.	Arborist Report # A1-1 Landscape Plan # Other #
EC.3.1	Biodiversity in landscapes	Plant landscaped site area using a minimum of 50% native species	100% of plants selected are drought tolerant. Schemes used in landscaping are not native to Ontario, but are drought tolerant and do not require irrigation or intervention.	Arborist Report # A1-1 Landscape Plan # Other #
EC.3.2	Reactive and natural areas buffers	Where a setback from top of bank is required, plant landscaped area in the setback with native species	N/A. No reserve adjacent to site.	Landscape Plan # A1-1 Other #
EC.3.3	Invasive species	No invasive species in landscape along streets, adjacent to streets and natural areas	No invasive species will be planted.	Landscape Plan # A1-1 Other #

TORONTO GREEN STANDARD VERSION 2.0 – CHECKLIST

For New Mid to High Rise Residential and all New Non-Residential Development
Complete in conjunction with the full Toronto Green Standard and Specifications.

Section	Development Feature	Tier 1 Required Performance Measure Summary	Description (How is this performance measure being met?)	Reference to Plans, Drawings or Reports
EC.4.1	Bird friendly glazing	Use a minimum of 25% of all exterior glazing with bird friendly glazing or bird friendly glazing	A combination of fitted glass, muted reflections, and opaque materials (low reflectance glazing) will be used to achieve 25% treated area within first 12m of the building.	Landscape Plan # A1-1 Other # A2.1, A2.2, A2.3, A2.4
EC.4.2	Roofing vegetation	Plant the first 4 m of glazing above the terrace	A combination of fitted glass, muted reflections, and opaque materials (low reflectance glazing) will be used to achieve 25% treated area within first 12m of the building.	Landscape Plan # A1-1 Other #
EC.4.3	Grate porosity	Grate porosity of less than 50 mm x 50 mm (or less than 50 mm x 50 mm)	As noted on Architectural drawings, any grate with a porosity of 50 mm x 50 mm will be installed on any ground-level ventilation grates.	Landscape Plan # A1-1 Other # A2.4
EC.5.1	Exterior lighting	Shield all exterior light fixtures	Cut-off fixtures will be specified to minimize light trespass. There are no lighting or unshielded fixtures within project scope.	Site Plan # A1-1 Landscape Plan # A1-1 Building Elevation # Other #

TORONTO GREEN STANDARD VERSION 2.0 – CHECKLIST

For New Mid to High Rise Residential and all New Non-Residential Development
Complete in conjunction with the full Toronto Green Standard and Specifications.

TIER 1: SOLID WASTE

Section	Development Feature	Tier 1 Required Performance Measure Summary	Description (How is this performance measure being met?)	Reference to Plans, Drawings or Reports
DW.1.1	Waste collection & sorting system	Residential: Provide a waste sorting system	A binocular will be provided for garbage and compost, with a separate chute provided for recycling at 2 locations, within the garage (east and west). A binocular will be provided for recyclable housing.	Floor Plan # A1-1 Other # A2.4, A2.8
DW.1.2	Waste storage spaces	Residential: Provide easily accessible waste storage room	Compost: 71 sq.m. of storage space is required. 100.0 sq.m. are provided. Affordability: 38 sq.m. of storage space is required. 78 sq.m. are provided.	Site Plan # A1-1 Underground Garage Plan # A1-1 Other #
DW.1.3	Bulky waste	Residential: Provide a minimum of 10 m² of bulky waste storage space for bulky waste and additional diversion programs	10 m² of storage space is provided for bulky waste and 10 m² of storage space is provided for bulky waste and 10 m² of storage space is provided for bulky waste.	Site Plan # A1-1 Underground Garage Plan # A1-1 Other #

TORONTO GREEN STANDARD VERSION 2.0 – CHECKLIST

For New Mid to High Rise Residential and all New Non-Residential Development
Complete in conjunction with the full Toronto Green Standard and Specifications.

Tier 2 is the voluntary, enhanced performance level. Site plan applications received on or after May 1, 2008 that meet both Tier 1 and Tier 2 of the Toronto Green Standard are eligible to apply for a potential rebate of development charges equivalent to 20% of the 2014 rate. Completion of Tier 2 involves meeting all of the performance measures identified below as CORE and selecting three performance measures identified as OPTIONAL. Indicate where Tier 2 performance measures will be documented in the right hand column of the checklist.

Tier 2 is verified during the construction stage by third party monitors required with the City. The detailed eligibility criteria, application and verification procedures are found at toronto.ca/development.

Section	Development Feature	Tier 2 Voluntary Performance Measure Summary	Description (How is this performance measure being met?)	Reference to Plans, Drawings or Reports
AQ.2.2	Enhanced UV	Remove 90% of total suspended solids based on the pre-development level of maintenance	The specified power has an SRP of 25.4. Prior to the start of the project, it was approved for the entire development to provide a consistent appearance throughout, and has already been installed along Merchants Wharf. Product selection is outside the scope of this design team.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
DW.1.3	Enhanced energy efficiency	Design and construct the building to achieve at least 25% energy efficiency improvement over the current Ontario Building Code	Building is designed to achieve at least 25% energy efficiency improvement over SB-10.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
DW.2.1	Building Commissioning	Commission the project using best practice commissioning	A Commissioning Authority has been appointed. Requirements will be met.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
WQ.4.2	Water Efficient Fixtures	Reduce potable water consumption by at least 20% using efficient water fixtures and appliances	Potable water use reduction target is 40% (as per LEED-2009 technology and Energy Star appliances will be used. Requirements will be met.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #

TORONTO GREEN STANDARD VERSION 2.0 – CHECKLIST

For New Mid to High Rise Residential and all New Non-Residential Development
Complete in conjunction with the full Toronto Green Standard and Specifications.

Section	Development Feature	Tier 2 Voluntary Performance Measure Summary	Description (How is this performance measure being met?)	Reference to Plans, Drawings or Reports
WQ.4.3	Irrigation	Reduce potable water use for irrigation by 50%	All irrigation requirements, including tree already adjacent to the site, will be met with harvested rainwater.	Landscape Plan # A1-1 Other # A2.1, A2.2, A2.3, A2.4
EC.5.2	Enhanced Lighting	Direct rooftop architectural illumination downward and turn off between the hours of 11 p.m. and 5 a.m. during majority of the year	Rooftop illumination will be directed downward. SAKS will be programmed to turn lights off overnight during migratory bird season.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
EC.5.3	Lighting Controls	Install an automatic device that reduces the intensity of interior lighting by 50% after 10 p.m.	Lobbies, amenity spaces, and retail will be equipped with sensors to switch off or reduce lighting by 50% between 11 p.m. and 5 a.m. as appropriate for the space type. Manual override will be set to 30 minutes or controlled via vacancy sensors.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #

TORONTO GREEN STANDARD VERSION 2.0 – CHECKLIST

For New Mid to High Rise Residential and all New Non-Residential Development
Complete in conjunction with the full Toronto Green Standard and Specifications.

TIER 2: OPTIONAL (SELECT 3)

Section	Development Feature	Tier 2 Voluntary Performance Measure Summary	Description (How is this performance measure being met?)	Reference to Plans, Drawings or Reports
AQ.1.2	Enhanced LEV spaces	Electrical provision for future electric vehicle charging	Electrical provision for future electric vehicle charging.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
AQ.2.3	Enhanced Bicycle parking rates	Provide enhanced bicycle parking rates	Enhanced bicycle parking rates.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
AQ.2.4	Shade trees	Provide public shade trees location at grade	Provide public shade trees location at grade.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
DW.1.4	On-site renewable energy	Design and install on-site renewable energy system	Design and install on-site renewable energy system.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
DW.2.2	Waters	Install thermal energy meters	Thermal meters will be installed to submeter heating and cooling energy used by the coils.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
WQ.2.3	Enhanced stormwater retention & reuse	Provide non-water downstorm retention and reuse	Provide non-water downstorm retention and reuse.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #

TORONTO GREEN STANDARD VERSION 2.0 – CHECKLIST

For New Mid to High Rise Residential and all New Non-Residential Development
Complete in conjunction with the full Toronto Green Standard and Specifications.

Section	Development Feature	Tier 2 Voluntary Performance Measure Summary	Description (How is this performance measure being met?)	Reference to Plans, Drawings or Reports
EC.1.3	Enhanced trees in parking lots	Plant drought-tolerant trees in surface parking areas	Plant drought-tolerant trees in surface parking areas.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
EC.2.3	Enhanced tree planting	Provide additional tree planting beyond the development site and the associated public boulevard	Provide additional tree planting beyond the development site and the associated public boulevard.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
EC.3.4	Enhanced Landscaping	Reactive or protect a minimum 50% of the site area or 25% of the total site area with native or drought-tolerant vegetation	Reactive or protect a minimum 50% of the site area or 25% of the total site area with native or drought-tolerant vegetation.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
EC.4.4	Enhanced bird friendly glazing	Use a combination of the following to achieve at least 25% of exterior glazing within the first 12 m of the building: a) Low reflectance opaque materials b) Visual markers c) Shade from structures covered by solar panels	Use a combination of the following to achieve at least 25% of exterior glazing within the first 12 m of the building: a) Low reflectance opaque materials b) Visual markers c) Shade from structures covered by solar panels	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
EC.4.5	Open building materials	Provide at least 50% of the exterior surface of the building is non-reflective opaque materials	Provide at least 50% of the exterior surface of the building is non-reflective opaque materials.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
DW.1.4	Enhanced waste collection & sorting	Provide three separate chutes for collection of each of the three waste streams on all floors (Residential)	Provide three separate chutes for collection of each of the three waste streams on all floors (Residential).	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #

TORONTO GREEN STANDARD VERSION 2.0 – CHECKLIST

For New Mid to High Rise Residential and all New Non-Residential Development
Complete in conjunction with the full Toronto Green Standard and Specifications.

Section	Development Feature	Tier 2 Voluntary Performance Measure Summary	Description (How is this performance measure being met?)	Reference to Plans, Drawings or Reports
DW.1.3	Enhanced waste storage space	One of the following is provided: a) Dedicated waste storage space for collection of three waste streams b) Dedicated waste storage space for collection and storage of recycling and compost	A dedicated area within the waste storage room will be designated for the collection of waste batteries, fluorescent light bulbs, and other household hazardous waste.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
DW.1.4	Household hazardous waste	Provide a dedicated collection area in vault	A dedicated area within the waste storage room will be designated for the collection of waste batteries, fluorescent light bulbs, and other household hazardous waste.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
DW.2.1	Building reuse	Maximum of least 50% of the existing building structure and envelope	Maximum of least 50% of the existing building structure and envelope.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
DW.2.2	Construction waste	Recycle at least 75% of non-hazardous construction and demolition debris	A waste diversion rate of at least 75% will be specified.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
DW.4.1	Recycled content	Ensure that at least 25% construction material comprise recycled content	Recycled content target for the project is 20%.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #
DW.5.1	Regional materials	Ensure at least 50% of the building materials or products have been sourced within 80 km of the final manufacturing site	Regional content target for the project is 20%.	Arborist Report # A1-1 Site Plan # A1-1 Landscape Plan # A2.1-A2.3 Tree Preservation Plan # Other #

Toronto Green Standard Version 2.0 Statistics Template

For New Mid to High-Rise Residential and All Non-Residential Development
The Toronto Green Standard Statistics Template is submitted with Site Plan Control Applications and stand alone Zoning Bylaw Amendment applications. Complete the table and copy it directly onto the Site Plan submitted as part of the application. (Simplified General Project Description and Section 116 Zoning Bylaw Amendment applications. Complete General Project Description, Section 1 and Section 2 for Site Plan Control applications. Refer to the full Toronto Green Standard for Mid to High-Rise Residential and All Non-Residential Development for the complete set of standards and detailed specifications. (www.toronto.ca/greendevstandards)

Toronto Green Standard Statistics	
General Project Description	Proposed
Total Gross Floor Area	27,565
Breakdown of project components:	
Residential	24,347
Retail	3,112
Commercial	106
Industrial	
Institutional/other	
Total number residential units (residential only)	227

Section 1: For Stand Alone Zoning Bylaw Amendment Applications and Site Plan Control Applications

</