



**MCW Consultants Ltd.**

# Site Instruction

Date: December 9, 2016

Queen's Quay Terminal  
207 Queen's Quay West, Suite 615  
Toronto, Ontario M5J 1A7

Phone (416) 598-2920  
Fax (416) 598-5394  
www.mcw.com

Project Name: AQUAVISTA - Bayside  
Client: TRIDEL Corporation  
To: TRIDEL Corporation  
Attention: Chadi Loza  
Fax number: -

Project No.: 8489D  
SI No.: E 009  
Page No.: 1 of 1+ 2 Attached  
Office: Toronto  
From: Sunanda Perera  
Tao Li

Distribution: Vince Mirarchi –TRIDEL  
Chadi Loza - TRIDEL  
Christina Lee -KIRKOR  
Al Medeiros –MCW  
Michael Hunter-MCW  
Mark Furtado-MCW  
Sarfraz H. Jaffrey-MCW

Provide itemized labour, equipment and material costs for Work listed below. Do not proceed with any of the listed Work prior to issuance of signed Change Order.

## Title: Electrical Room Rearrangement.

### Specification:

Spec	Issued	Items
		• N/A

### Electrical:

Drawing No.	Drawing Issued	Items
E05-01	No	<ul style="list-style-type: none"> <li>Add exit signs, lighting fixtures and control switches in electrical room as shown.</li> <li>Add fire alarm smoke detector and speak in electrical room as shown.</li> </ul> <u>Clarification to electrical room layout-</u> <ul style="list-style-type: none"> <li>Rearrange electrical panel layout in main electrical room (contractor proposed layout)</li> <li>Elevation drawing is added for main electrical room. Refer Detail 14.</li> </ul>

### ME Schedule:

Drawing No.	Drawing Issued	Items
-	-	• N/A.

---

**Reason for Issue – Design Coordination/Hydro Comments/Contractor proposed room layout.**

**End of SI-E009**

