



MCW Consultants Ltd.

Site Instruction

Date: December 04, 2015

207 Queen's Quay West, Suite 615
Toronto, ON
M5J 1A7

Phone (416) 598-2920
Fax (416) 598-5394
www.mcw.com

Project Name: The Residences of 10 York
Client: Tridel
To: Tridel
Attention: Marius Hirboca

Project No.: 8503
SI No.: M013
Page No.: 1 of 1 + attach
Office: Toronto
From: Pol Malabanan
Sarfraz Jaffrey

Distribution: **Tridel:**
Vince Mirarchi
Wallman Architects
John Harhay
MCW Consultants Ltd
Michael Hunter
Pol Malabanan
Al Medeiros
Sunanda Perera
Vito Mazzaro

Provide itemized labour, equipment and material costs for Work listed below. Do not proceed with any of the listed Work prior to issuance of signed Change Order.

Title: Miscellaneous Revisions

Mechanical Drawings:

Drawing #	Issued	Items
M1-01	Yes	<ul style="list-style-type: none"> • Provided ventilation system (EF-80 to EF-82 c/w associated intake/exhaust grilles) on new lockers as shown. • Provided wall mounted fire extinguisher (FE) as shown.
M1-02	Yes	<ul style="list-style-type: none"> • Provided ventilation system (EF-83 to EF-88 c/w associated intake/exhaust grilles) on new lockers as shown. • Provided wall mounted fire extinguisher (FE) as shown.
M1-03	Yes	<ul style="list-style-type: none"> • Provided ventilation system (EF-89 to EF-91 c/w associated intake/exhaust grilles) on new lockers as shown. • Provided wall mounted fire extinguisher (FE) as shown.

ME Schedules:

Drawing #	Issued	Items
ME-03	Yes	<ul style="list-style-type: none"> • Add EF-80 to EF-91

Reason for Revision: To suit architectural changes.

End of SI-M013

EXHAUST / SUPPLY AIR FAN SCHEDULE

REFERENCE	DESCRIPTION	LOCATION	SERVING	EXHAUST AIR (L/S)	E.S.P. (KPA)	FAN (RPM)	WEIGHT (KG.)	P.W.L. db RE 10"12 WATTS OCTAVE BAND								MANUFACTURER	MODEL	ENERGY REQUIRED (HP)	MOTOR SIZE (KW)	POWER SUPPLY		STARTER		TYPE	CONTROLS		OTHER REQUIREMENTS		REMARKS	NOTES								
								1	2	3	4	5	6	7	8					VOLTS	PHASE	FED FROM	DM		NORM.	SUPPLIED BY	INSTALLED BY	MANUAL			AUTO.	INTERLOCK BY:	DISC. AT MOTOR	W.P. DISC. AT MOTOR	F.A. SHUT	OTHERS		
EF-01	PARKING EXHAUST	P5 PARKING	P5 PARKING	11800	0.08	624	230	-	-	-	-	-	-	-	-	-	GREENHECK	SBS-2142-50	3.7	575	3	6E3MA-1,3,5	YES	-	DV 15	DV 15	255WR	-	YES	YES	-	YES	-	-	-	-	-	-
EF-02	PARKING EXHAUST	P4 PARKING	P4 PARKING	11800	0.08	624	230	-	-	-	-	-	-	-	-	GREENHECK	SBS-2142-50	3.7	575	3	6E3MA-7,9,11	YES	-	DV 15	DV 15	255WR	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-03	PARKING EXHAUST	P3 PARKING	P3 PARKING	11800	0.08	624	230	-	-	-	-	-	-	-	-	GREENHECK	SBS-2142-50	3.7	575	3	6E3MA-13,15,17	YES	-	DV 15	DV 15	255WR	-	YES	YES	-	YES	-	-	-	-	-	-	-
EF-04	PARKING EXHAUST	P2 PARKING	P2 PARKING	11800	0.08	624	230	-	-	-	-	-	-	-	-	GREENHECK	SBS-2142-50	3.7	575	3	6E3MA-19,21,23	YES	-	DV 15	DV 15	255WR	-	YES	YES	-	YES	-	-	-	-	-	-	-
EF-05	PARKING EXHAUST	P1 PARKING	P1 PARKING	10856	0.08	624	230	-	-	-	-	-	-	-	-	GREENHECK	SBS-2142-50	3.7	575	3	6E3MA-25,27,29	YES	-	DV 15	DV 15	255WR	-	YES	YES	-	YES	-	-	-	-	-	-	-
EF-06	RES. STG. EXHAUST	P5 RES. STOR	P5 RES. STOR	142	0.06	1300	25	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-6	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-07	BI-CYCLE STG. EXH	P5 BI-CYCLE STG.	P5 BI-CYCLE STG.	142	0.06	1300	25	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-2	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-08	RES. STG. EXHAUST	P5 RES. STOR	P5 RES. STOR	38	0.05	1300	15	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-2	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-09	RES. STG. EXHAUST	P5 RES. STOR	P5 RES. STOR	43	0.05	1300	15	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-2	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-10	RES. STG. EXHAUST	P5 RES. STOR	P5 RES. STOR	19	0.05	1300	15	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-6	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-11	RES. STG. EXHAUST	P5 RES. STOR	P5 RES. STOR	109	0.05	1600	25	-	-	-	-	-	-	-	-	GREENHECK	50-70-VG	0.12	115	1	2P1M-4	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-12	RES. STG. EXHAUST	P5 RES. STOR	P5 RES. STOR	57	0.05	1300	15	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-4	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-13	RES. STG. EXHAUST	P5 RES. STOR	P5 RES. STOR	48	0.05	1300	15	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-4	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-14	RES. STG. EXHAUST	P5 RES. STOR	P5 RES. STOR	38	0.05	1300	16	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-4	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-15	RES. STG. EXHAUST	P5 RES. STOR	P5 RES. STOR	142	0.07	1300	22	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-2	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-16	RES. STG. EXHAUST	P4 RES. STOR	P4 RES. STOR	142	0.07	1300	22	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-6	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-17	BI-CYCLE STG. EXH	P4 BI-CYCLE STG.	P4 BI-CYCLE STG.	142	0.06	1300	22	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-10	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-18	RES. STG. EXHAUST	P4 RES. STOR	P4 RES. STOR	38	0.05	1300	16	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-10	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-19	RES. STG. EXHAUST	P4 RES. STOR	P4 RES. STOR	43	0.05	1300	15	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-10	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-20	RES. STG. EXHAUST	P4 RES. STOR	P4 RES. STOR	19	0.05	1300	16	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-8	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-21	NOT USED	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
EF-22	RES. STG. EXHAUST	P4 RES. STOR	P4 RES. STOR	48	0.05	1300	15	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-12	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	-
EF-23	RES. STG. EXHAUST	P4 RES. STOR	P4 RES. STOR	38	0.05	1300	16	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-12	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	-
EF-24	RES. STG. EXHAUST	P3 RES. STOR	P3 RES. STOR	142	0.07	1300	22	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-14	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-25	BI-CYCLE STG. EXH	P3 BI-CYCLE STG.	P3 BI-CYCLE STG.	142	0.06	1300	22	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-16	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-26	RES. STG. EXHAUST	P3 RES. STOR	P3 RES. STOR	38	0.05	1300	16	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-16	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-27	RES. STG. EXHAUST	P3 RES. STOR	P3 RES. STOR	43	0.05	1300	15	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-16	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-28	RES. STG. EXHAUST	P3 RES. STOR	P3 RES. STOR	19	0.05	1300	16	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-14	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-29	NOT USED	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
EF-30	RES. STG. EXHAUST	P3 RES. STOR	P3 RES. STOR	48	0.05	1300	15	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-18	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-31	RES. STG. EXHAUST	P3 RES. STOR	P3 RES. STOR	38	0.05	1300	16	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-18	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-32	RES. STG. EXHAUST	P2 RES. STOR	P2 RES. STOR	142	0.07	1300	22	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-20	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-33	FIRE PROT. RM EXH	P2 FIRE PROT. RM	P2 FIRE PROT. RM	284	0.06	1300	25	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.06	115	1	2P1M-22	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-34	RES. STG. EXHAUST	P2 RES. STOR	P2 RES. STOR	38	0.05	1300	16	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-22	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-35	RES. STG. EXHAUST	P2 RES. STOR	P2 RES. STOR	43	0.05	1300	15	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-22	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-36	RES. STG. EXHAUST	P2 RES. STOR	P2 RES. STOR	19	0.05	1300	16	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-20	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-37	NOT USED	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-				
EF-38	RES. STG. EXHAUST	P2 RES. STOR	P2 RES. STOR	48	0.05	1300	15	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-24	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-39	RES. STG. EXHAUST	P2 RES. STOR	P2 RES. STOR	38	0.05	1300	16	-	-	-	-	-	-	-	-	GREENHECK	50-60-G	0.05	115	1	2P1M-24	-	YES	DV 15	DV 15	MEDIA V BELLY	-	YES	YES	-	YES	-	-	-	-	-	-	
EF-4																																						